

ELECTRIC CORPORATION OF ECUADOR



Abitagua
Hidroelectric
Project



LOCATION

Abitagua Hidroelectric Project

Ecuador
Galápagos



The Abitagua hydroelectric project is located in the lower basin of the Pastaza River, between the provinces of Tungurahua, Pastaza and Morona Santiago.





The accessibility of the project is good as it is located along the existing Baños-Puyo highway. This highway has excellent conditions for the provision and removal of construction materials and debris.


The conformation of roads with a width of 6 m is planned, with side slopes with a 1:2 inclination and with improvement of the roadway through compaction and placement of a material layer of compacted subbase material as wearing course.

For access to the alternative selected in the prefeasibility study, the improvement of the current access road to the “Tres Cascadas” farm is identified as the best option. From this existing road, new roads will have to be created for machinery access to the river and to implantation sites of the diversion and dam works, as well as for the provision and removal of construction material and debris.





GENERAL DESCRIPTION



In the prefeasibility phase, a series of alternatives were studied for energy development, the main characteristics of the selected alternative (number 7) were the following:



Dam

The dam consists of a conventional gravity-arch shaped type structure in roller compacted concrete of approximately 66 m high and 350 m long at the crown of the dam.



Hydraulic Circuit

The hydraulic circuit is sized to carry the design flow rate of 200 m³/s and it's made up of the intake or catchment work, a 100 m long loading tunnel a 71.50 m long vertical well, a 50 m long penstock with its respective bifurcation and a 3,522 m long discharge tunnel.



Surge Tank

Given the length of the discharge tunnel, the installation of a surge tank has been planned so that it absorbs the oscillations of mass resulting from the untimely start-up or shutdown of the turbines. The surge tank will consist of a tunnel with a regular arch section, unlined (except for the crest) of 9.0 m high by 9.0 m wide, developed over a length of 300 m.



Interconnection



As an alternative for the interconnection of the Abitagua power plant in the prefeasibility studies, there is a connection to the Topo substation, for which a 230 kV yard must be expanded and installed in this substation. A 230 kV transmission line must be extended from the Topo substation to the San Francisco-Totoras transmission system. The connection scheme and number of circuits should be defined in subsequent studies.

The planned powerhouse is underground or in a cavern and will accommodate 2 vertical axis Francis turbines fed from the bifurcation of the penstock.

Power House



The planned dimensions of the powerhouse are approximately 70 m x 19.90 m in plan, where the caverns of the transformer, substation, and gates at the exit of the turbine diffusers will be housed.



Pre-feasibility plant alternatives studied





TECHNICAL DETAILS




	Level of study	Prefeasibility		
	Existing studies	<ul style="list-style-type: none"> • Topography and Cartography • Hydrology • Sedimentology • Geology y geotechnics • Environmental baseline • Hydro energy 		
	Power (MW)	165,3	Energy (GWh/year)	1114
	Estimated plant factor (%) and design flow	77% - 200 m ³ /s	Study completion date	Year 2019
	Estimated construction time	48 months		
	Estimated construction budget	489 (MM USD)	Civil works 326MM UDS Hydro-electro-mechanical works 163 MM USD	





For the project
area the following
characteristics
were evaluated





Futuro Energético

